

Service Company
 44 Barkely Circle
 Fort Myers FL 33907
 Phone: 800-226-7529
 Fax: 239-275-1979

INVOICE

DATE	INVOICE #	CUST #
12/11/2013	0000001877	0000670

BILL TO:

John Doe
 123 dESCO Drive
 Fort Myers FL 33907

SHIP TO:

John's Office
 456 Main St.
 Paradise City FL 33904

P.O. NUMBER		TERMS	SALES PERSON	
J18913		COD	Ron	
QUAN	DESCRIPTION		PRICE EACH	AMOUNT
1.00	000706P	Foam Filter 14x23x1/4" Reinfor	3.22	3.22
1.00	000615P	Universal Thermostat Kit	64.40	64.40
Unit is running but is blowing warm air. Also, water is dripping from ceiling below handler. Please change out filters while you're there. Air handler was off balance, pan was overflowing. Drained pan and leveled air handler. Replaced filters in offices and upgraded thermostat. - Austin				
SUBTOTAL				\$67.62
TAX				\$4.06
TOTAL				\$71.68