

PACKING LIST

Service Company
44 Barkely Circle
Fort Myers FL 33907
Phone: 800-226-7529
Fax: 239-275-1979

DATE

12/11/2013

INVOICE #

0000001877

CUST #

0000670

BILL TO:

John Doe
123 dESCO Drive
Fort Myers FL 33907

SHIP TO:

John's Office
456 Main St.
Paradise City FL 33904

P.O. NUMBER		TERMS	SALES PERSON
J18913		COD	
QUAN	DESCRIPTION		
1.00	000706P	Foam Filter 14x23x1/4" Reinfor	
1.00	000615P	Universal Thermostat Kit	
		Unit is running but is blowing warm air. Also, water is dripping from ceiling below handler. Please change out filters while you're there.	
		Air handler was off balance, pan was overflowing. Drained pan and leveled air handler.	
		Replaced filters in offices and upgraded thermostat. - Austin	